



**THOMPSON
& LITTON** EST.
1956

ENGINEERS ARCHITECTS SURVEYORS



ADDENDUM NO. 003

TO: All Plan Holders

RE: Water System Capital Improvements – Phase II
For Town of Bluefield
T&L Project No. 16176

DATE: June 21, 2023

BIDS RECEIVED DATE: June 28, 2023

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated May 5, 2023, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

This Addendum consists of 1 page with no enclosures.

CLARIFICATIONS AND ANSWERS TO PRE-BID QUESTIONS:

1. All generators are specified with a weatherproof enclosure for use outdoors. The specification requires that the fuel port be accessible from the outside of the enclosure to reduce fuel spills within the enclosure.

CHANGES TO DRAWINGS:

1. Single phase generators will be provided with 1.0 PF in lieu of 0.8 PF shown on plans. Revised drawings are not attached.